

Consumer Confidence Report

Annual Drinking Water Quality Report

SHARPSBURG AND NEIGHBORING AREA WATER SY

IL0210030

Annual Water Quality Report for the period of January 1 to December 31, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by

SHARPSBURG AND NEIGHBORING AREA WATER SY is Purchased Ground Water

For more information regarding this report contact:

Name Jake Herberling

Phone 217 325 3621

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo o hable con alguien que lo entienda bien.

Source of Drinking Water	
The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.	Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.
Contaminants that may be present in source water include: <ul style="list-style-type: none">- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.	<p>In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.</p> <p>Some people may be more vulnerable to contaminants in drinking water than the general population.</p> <p>Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).</p> <p>Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier</p>

to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact William C. Stewart 817 325 3621. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name

CC01 - MASTER METER

Type of Water

GW

Report Status

A

Location

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 217-325-3621 To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: STONINGTON To determine Stonington's susceptibility to groundwater contamination, a Well Site Survey, published in 1990 by the Illinois EPA, and a Source Water Protection Management Plan were reviewed. Based on the information obtained in these documents, one potential source, route, or possible problem site is located within the combined 400 foot minimum setback zones of wells #11, #12, and #13. An additional potential source of contamination, route, or problem site is present within the Phase II Wellhead Protection Area (WHPA) of the wells that could pose a hazard to groundwater utilized by the Stonington community water supply wells. A Phase II WHPA, also referred to as the recharge area, is the geographic area surrounding a well or a well field providing potable water to a community water supply as modeled using computer software to determine a five-year time of travel. All of the land use around Stonington's wells (approximately 98 acres) in the combined Phase I and Phase II WHPAs is classified as agriculture. The United States Department of Agriculture (USDA) describes this Land Resource Region as the Central Feed Grains and Livestock Region. Further, USDA classifies this Major Land Resource Area as the Illinois and Iowa Deep Loess and Drift, East-Central Part. The Cl/Br vs. Cl ratio indicates non-point source agriculture fertilizer, as a possible source of nitrate in the area of the wells. The nitrate concentrations for well #12 ranged from 2.32 - 5.58 mg/L during the bi-monthly sample collection starting in December 2014 and continuing through November 2016. Figure 2 illustrates the overall slightly decreasing trend in nitrate concentration and an increasing trend in chloride. The Illinois EPA considers Stonington's source water susceptible to SOC contamination. The source water is not considered to be susceptible to VOC contamination. The SOC and VOC susceptibility determination is based on the land use within the recharge area of the wells (see Potential Sources of Contamination section). As a result of monitoring conducted at the wells and entry point to the distribution system, the land use activities, and source water protection initiatives by the city (refer to the following section of this report), the Stonington Community Water Supply's source water is not susceptible to IOC contamination. All public water supplies using groundwater are required to sample their wells monthly for bacterial contaminants. Sampling performed to assess for pathogenic contamination (e.g., virus, total coliform, e-coli) has demonstrated that the source water is not susceptible to these types of contaminants.

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: ND to 122 ug/L

Lead Range: ND to ND

To obtain a copy of the system's lead tap sampling data:

Village of Stonington 217 325 3621

CIRCLE ONE: Our Community Water Supply has/has not developed a service line material inventory.

To obtain a copy of the system's service line inventory:

Village of Stonington 217 325 3621

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1.3	1.3	0.111	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na:

not applicable.

Water Quality Test Results

mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1.5	1.11 - 1.6	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2024	1	1.3 - 1.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	17	17 - 17	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Consumer Confidence Report

Annual Drinking Water Quality Report

STONINGTON
IL0210550
Annual Water Quality Report for the period of January 1 to December 31, 2024
This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by
STONINGTON is Ground Water

For more information regarding this report contact:

Name Jake Heberling
Phone 217 325-3621

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo o hable con alguien que lo entienda bien.

Source of Drinking Water
The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
Contaminants that may be present in source water include: - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. - Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier

to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact 214 325 3621 information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name	Type of Water	Report Status	Location
WELL 11 (50097)	GW	<u>A</u>	250 FT S OF WELL 10
WELL 12 (01739)	GW	<u>A</u>	121 FT S, 70 FT W OF NW CORNER SE 1/4 SEC 34, T 14 N, R1W, 3RD PM
WELL 13 (02053)	GW	<u>A</u>	

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 217 325 3621. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: STONINGTON To determine Stonington's susceptibility to groundwater contamination, a Well Site Survey, published in 1990 by the Illinois EPA, and a Source Water Protection Management Plan were reviewed. Based on the information obtained in these documents, one potential source, route, or possible problem site is located within the combined 400 foot minimum setback zones of wells #11, #12, and #13. An additional potential source of contamination, route, or problem site is present within the Phase II Wellhead Protection Area (WHPA) of the wells that could pose a hazard to groundwater utilized by the Stonington community water supply wells. A Phase II WHPA, also referred to as the recharge area, is the geographic area surrounding a well or a well field providing potable water to a community water supply as modeled using computer software to determine a five-year time of travel. All of the land use around Stonington's wells (approximately 98 acres) in the combined Phase I and Phase II WHPAs is classified as agriculture. The United States Department of Agriculture (USDA) describes this Land Resource Region as the Central Feed Grains and Livestock Region. Further, USDA classifies this Major Land Resource Area as the Illinois and Iowa Deep Loess and Drift, East-Central Part. The Cl/Br vs. Cl ratio indicates non-point source agriculture fertilizer, as a possible source of nitrate in the area of the wells. The nitrate concentrations for well #12 ranged from 2.32 - 5.58 mg/L during the bi-monthly sample collection starting in December 2014 and continuing through November 2016. Figure 2 illustrates the overall slightly decreasing trend in nitrate concentration and an increasing trend in chloride. The Illinois EPA considers Stonington's source water susceptible to SOC contamination. The source water is not considered to be susceptible to VOC contamination. The SOC and VOC susceptibility determination is based on the land use within the recharge area of the wells (see Potential Sources of Contamination section). As a result of monitoring conducted at the wells and entry point to the distribution system, the land use activities, and source water protection initiatives by the city (refer to the following section of this report), the Stonington Community Water Supply's source water is not susceptible to IOC contamination. All public water supplies using groundwater are required to sample their wells monthly for bacterial contaminants. Sampling performed to assess for pathogenic contamination (e.g., virus, total coliform, e-coli) has demonstrated that the source water is not susceptible to these types of contaminants.

2024 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: ND to 128 ug/L
Lead Range: ND to ND ug/L

To obtain a copy of the system's lead tap sampling data: Village of Stonington 217 325 3621

CIRCLE ONE: Our Community Water Supply has/has not developed a service line material inventory.

To obtain a copy of the system's service line inventory: Village of Stonington 217 325 3621

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1.3	1.3	0.0651	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

Water Quality Test Results

mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1.5	1.22 - 1.6	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2024	4	4 - 4	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2024	22	22 - 22	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	10/16/2023	0.0124	0.0124 - 0.0124	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	10/16/2023	0.77	0.77 - 0.77	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (measured as Nitrogen)	2024	5	4.18 - 4.72	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	10/16/2023	77400	77400 - 77400			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.